




Make Up Water flow meter installation notes.


- Meter upstream of control valve (always pressurized).

Tower drain flow meter installation notes.

- Meter always in full pipe.
- Trap deep enough to ensure no bubbles at meter.
- Follow all directions in meter's manual.
 - Straight run, orientation.
 - Electronics environmental ratings.
 - Power & signal wiring.

Symbol Key

-  Onicon flow meter
-  Blow down valve
-  Makeup valve (level operated)

| | | | | | |
|---|-------|---|----|---|--|
| Bayside HVAC Products LLC 415-333-5099 dan@baysidehvac.com | |  | | Cooling Tower Metering Drain, Makeup Water | |
| DATE | SCALE | REV | BY | FILENAME | |
| 4/4/2019 | NTS | 2 | DS | TOWER DRAIN + MU 4-19.VSD | |